



REACTION TO FIRE CLASSIFICATION REPORT  
N° 2018/130-2

(English version of classification report N°2018/130-1)

According to EN 13501-1 (2007) + A1 (2013)

Notification by the French Government to the European Commission  
under n° NB 2401  
Regulation (UE) n° 305/2011

Sponsor : ESTIVAL  
80 rue Joffroy d'Abbans  
75017 PARIS  
FRANCE

Product group : FLORATEC R403 – FLORATEC R507 – EBENBILD  
Premium R507 – FLORATEC R3515 – EBENBILD  
Premium R3515 – EBENBILD Premium R4055

Description : Resilient floor coverings (EN ISO 10582 family)  
(see detailed description in paragraph 2)

Date of issue : 16/01/2019 (update)

*The indicated classification does not prejudge the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law dated June 3<sup>rd</sup> 1994.*

*The reproduction of this classification report is only authorised in its integral form.  
It comprises 4 pages*

## 1. Introduction

This classification report defines the classification assigned to the above-mentioned product (s) in accordance with the procedures given in the NF EN 13501-1 standard: September 2007 & A1 (2013).

## 2. Details of classified product

### 2.1. Product standard

NF EN 14041 (2005):“Resilient, textile and laminate floor coverings - Essential characteristics “.

### 2.2. Product description

Heterogeneous polyvinyl chloride floor covering in LVT size of 1240 mm x 225 mm and 1220 mm x 180 mm (EN ISO 10582 family).

Tested loose laid over a wood panel particle board without flame retarded classified C<sub>fl-s1</sub> with a density (680 ± 50) kg/m<sup>3</sup> and thickness (20 ± 2) mm.

Use surface: 100 % PVC

Type of backing: PVC

Nominal mass per unit area : 6800 to 9500 g/m<sup>2</sup>

Nominal total thickness : 3,50 to 5,00 mm

Nominal wear layer thickness : 0,15 to 0,70 mm

## 3. Test reports and tests results in support of this classification

### 3.1. Tests reports

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	ESTIVAL 80 rue Joffroy d'Abbans 75017 PARIS FRANCE	RL 2018/965-1	NF EN ISO 9239-1
		RL 2018/967-1	
		RL 2018/965-2	NF EN ISO 11925-2
		RL 2018/967-2	

### 3.2. Tests results

Test method	Product	Number of tests	Results	
			Parameters	Compliance parameters
NF EN ISO 11925-2	FLORATEC R3515 EBENBILD Premium R3515	6	Fs ≤ 150 mm	Compliant
Surface exposure-15 secondes			Ignition of the filter paper	Compliant

Test method	Product	Number of tests	Results	
			Parameters	Compliance parameters
NF EN ISO 11925-2	FLORATEC R507 EBENBILD Premium R507	6	Fs ≤ 150 mm	Compliant
Surface exposure-15 secondes			Ignition of the filter paper	Compliant

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	FLORATEC R3515 EBENBILD Premium R3515	3	Critical heat flux (kW/m <sup>2</sup> )	≥ 11
			Smoke (% X min)	105,3

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	FLORATEC R507 EBENBILD Premium R507	3	Critical heat flux (kW/m <sup>2</sup> )	≥ 11
			Smoke (% X min)	153,5

#### 4. Classification and field of application

##### 4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1 :2007 & A1 (2013).

##### 4.2. Classification

Fire behaviour		Smoke production
B <sub>fl</sub>	-	s1

**Classification : B<sub>fl</sub> – s1**

##### 4.3. Field of application

This classification is valid for the following end use applications :

Loose laid and glued over a wood panel particle board without flame retarded classified C<sub>fl</sub>-s1 with a density ≥ 510 kg/m<sup>3</sup> and over a fibre-cement A2<sub>fl</sub> or A1<sub>fl</sub> class with a density ≥ 1350 kg/m<sup>3</sup>.

This classification is valid for the following product parameters :

- A nominal mass per unit area of: 6800 to 9500 g/m<sup>2</sup>
- A nominal thickness of : 3,50 to 5,00 mm
- A nominal wear layer thickness of : 0,15 to 0,70 mm

#### 5. Limitations


This classification document does not represent type approval or certification of the product.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.”

Head of Tests  
David VANDIERDONCK



For the SARL C.R.E.T.  
The Technical Director  
Marc WELCOMME



*End of the classification report*